

Attachment 3

June 23, 1995

TO: Nick Masla, CIP Coordinator
Facilities Management Division

FR: Spencer Beffington, Supervisor
Construction Section

RE: Airport EMF Building - PCB's Disposal Estimate

Per your request, we estimate the removal and proper disposal of all the PCB's light ballast's in the EMF building will cost \$57,665.00. This estimate is based only on the light fixtures already being disconnected and laying on the floor or brought to one location. If the asbestos crew has to disconnect and remove the light fixtures, then the estimate would be re-evaluated to include fixture demolition.

If there are any further questions, please contact me at 6-0116 or Van Pham at 6-0651.

file

cc; Van Pham, Asbestos Surveyor/Coordinator. Facilities Management Division

KCSlip4 37271

SEA403816